

PS 2500-PM-3S-FC-Super-Native BACnet



Main Controller All-IN-ONE[™] Fan-Coils with proportional outputs (3-wire) for Cool and Heat valves, with Native BACnet Protocol

General

The PS 2500-PM-3S-FC-SUPER is a main controller for Fan coils applications with BACnet Protocol.

The PS 2500-PM-3S-FC-SUPER has most of the applications built-in, field selectable.

This flexibility gives the customers the advantage of having one main controller for most of Fan coils applications. The PS 2500-PM-3S-FC-SUPER has a modular and modern design for the high requirements of the market today. The PS 2500-PM-3S-FC-SUPER is factory pre-program to save valued time on field programming.

Features

- All-In-One system for Fan Coil applications
- Main Input- 220Vac
- Applications with jumper selection:
 - 2-pipe systems
 - 4-pipe systems
 - no valves system

 Proportional outputs (3-wire) for Cool and Heat valves- 24Vac with external transformer

(open/close time adjustable through protocol)


 Auto-change over sensor (Mode is set based on temperature of the incoming water flow, ideal for 2-pipe systems)

- Discharge sensor- option (2-pipe systems)
- 3 Speeds output- 220Vac, 3Amp each- with Auto Speed function
- Indoor coil sensor for Heat (soft-start)
- Surface and flush mount thermostats- option
- Fault input dry contact, voltage-free, for

occupancy sensor, window contact or fault input

Occupancy sensor- option with 12Vdc supply

PS 2500-PM-3S-Fan Coil-Super-Native BACnet



[Dimensions	
	Length	150 mm
	Width	83 mm
	Height	17 mm

SpecificationsTemperature Range10-30°CWeight0.250 KgScale°CAccuracy±1°CFlammabilityUL94V-0

Accessories	
Part Number	Description
FMH 2500	FMH - 2500 – Flush Mount panel- Horizontal
ETN 2500	ETN - 2500 – Surface Mount panel
FMT 2500	FMH - 2500 – Flush Mount panel- Vertical
IRP 2500	Receiver panel for remote control
RT03	IR remote control
TS01	Temperature Sensor - 80 cm Cable
RS01	Temperature Sensor into decorative box
RS02	Average Temperature Sensor into decorative box
RS03	Room Temperature Sensor ±3°C
WP4	Decorative back plate for ETN panel



PS 2500-PM-3S-Fan Coil-Super-Native BACnet

Configurations



Main Board

PS2500 - Main Controller All-IN-ONE[™] for Fan-Coils applications with Native BACnet Protocol

Control Panels / Accessories



ETN-X500 – Wall mount thermostat with built in temperature sensor* and LCD display.



FMH-X500 – Flush mount thermostat with built in temperature sensor* and LCD display.



IRP-X500 - Receiver Panel with built in temperature sensor* + IR Remote Control unit.

K

TS01 – Return air sensor ONLYconnected to main board. NO wall panel needed.

*The temperature may be sensed either through the wall panel's built in temperature sensor **OR** through the return air sensor connected to the main board (DIP Switch selectable).

file: ps2500-pm-3s-fc-super.ppt rev.2 date: 21.05.2006

Sample Object List

meitav-tec

IMPORTANT: The following Object List is for example purposes ONLY and will vary according to each specific project.

N	Object	Description	Value	Default	Remarks
1	Analog Input #0	T1- Return air sensor	7°C32°C		-
2	Analog Input #1	T2- Discharge sensor	-65°C150°C		-
3	Analog Input #2	T3- Indoor coil sensor	-65°C200°C		-
4	Analog Input #3	Cool / Heat value	0%100%		Indication
5	Analog Value #0	Set Point	10°C30°C		-
6	Analog Value #1	0= Fan Only, 1= Cool, 2= Heat, 3= Auto Change	Mode	Cool	Auto Change- ONLY for 4-pipe systems Fan Only- selectable option (shorting terminals F5,0)
7	Analog Value #2	0= Auto Speed, 1= Low, 2= Med, 3=High	Fan	Low	-
8	Analog Value #3	Dead zone Cool	0.5°C5.0°C	1.0°C	Only for Auto Change
9	Analog Value #4	Dead zone Heat	0.5°C5.0°C	1.0°C	Only for Auto Change
10	Analog Value #5	Offset T1 ambient	-6.0°C6.0°C	0.0°C	For display on thermostat
11	Analog Value #6	Differential (for Cool, Heat)	2.0°C10.0° C	2.0°C	-
12	Analog Value #7	Set Point Limit Low	10°C30°C	10°C	Does not limit display
13	Analog Value #8	Set Point Limit High	10°C30°C	30°C	Does not limit display
14	Binary Output #0	Thermostat On / Off	Off /On		-
15	Binary Input #0	Cooling	Off /On		Indication
16	Binary Input #1	Heating	Off /On		Indication
17	Binary Input #2	Fan: Speed Low	Off /On		Indication
18	Binary Input #3	Fan: Speed Medium	Off /On		Indication
19	Binary Input #4	Fan: Speed High	Off /On		Indication
20	Binary Input #5	Fault Input- F4 (all units OFF)	Off /On		Indication
21	Binary Input #6	IR Input- 12/IR	Off /On		Indication
22	Binary Input #7	Fault Input- F6 (indication only in protocol)	Off /On		Indication